# Specifications

## Eaton 216828

Eaton Moeller® series M22 Illuminated selector switch actuator, RMQ-Titan, With thumb-grip, maintained, 2 positions, green, Bezel: black

| General specifications | |
|---|---|
| **PRODUCT NAME** | Eaton Moeller® series M22 illuminated selector switch |
| **CATALOG NUMBER** | 216828 |
| **MODEL CODE** | M22S-WRLK-G |
| **EAN** | 4015082168285 |
| **PRODUCT LENGTH/DEPTH** | 46 mm |
| **PRODUCT HEIGHT** | 30 mm |
| **PRODUCT WIDTH** | 30 mm |
| **PRODUCT WEIGHT** | 0.013 kg |
| **CERTIFICATIONS** | IEC/EN 60947-5<br>UL File No.: E29184<br>IEC/EN 60947<br>CSA Class No.: 3211-03<br>VDE 0660<br>CSA-C22.2 No. 14-05<br>CSA-C22.2 No. 94-91<br>UL Category Control No.: NKCR<br>CSA<br>CE<br>CSA File No.: 012528<br>UL<br>UL 508<br>DNV |

## Actuator

| | |
|---|---|
| **ACTUATOR COLOR** | Black |
| **ACTUATOR FUNCTION** | Maintained<br>Switching function latching |
| **ACTUATOR TYPE** | Toggle |
| **BEZEL COLOR** | Black |
| **BEZEL MATERIAL** | Plastic |
| **DESIGN** | With thumb-grip<br>Classical |
| **FITTED WITH:** | Front ring |
| **FUNCTIONS** | Stay-put/spring-return function, can be changed with coding parts M22-XC-Y |
| **INDICATOR COLOR** | Green |
| **LENS TYPE** | Round |
| **NUMBER OF SWITCH POSITIONS** | 2 |

## Communication

| | |
|---|---|
| **CONNECTION TO SMARTWIRE-DT** | With SWD-RMQ connections<br>Yes |

## Climatic environmental conditions

| | |
|---|---|
| **AMBIENT OPERATING TEMPERATURE - MAX** | 70 °C |
| **AMBIENT OPERATING TEMPERATURE - MIN** | -25 °C |
| **CLIMATIC PROOFING** | Damp heat, constant, to IEC 60068-2-78<br>Damp heat, cyclic, to IEC 60068-2-30 |

## Design verification

| | |
|---|---|
| **10.10 TEMPERATURE RISE** | Not applicable. |
| **10.11 SHORT-CIRCUIT RATING** | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| **10.12 ELECTROMAGNETIC COMPATIBILITY** | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| **10.13 MECHANICAL FUNCTION** | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| **10.2.2 CORROSION RESISTANCE** | Meets the product standard's requirements. |
| **10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES** | Meets the product standard's requirements. |
| **10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT** | Meets the product standard's requirements. |
| **10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS** | Meets the product standard's requirements. |
| **10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION** | Please enquire |
| **10.2.5 LIFTING** | Does not apply, since the entire switchgear needs to be evaluated. |
| **10.2.6 MECHANICAL IMPACT** | Does not apply, since the entire switchgear needs to be evaluated. |

| | |
|---|---|
| **10.2.7 INSCRIPTIONS** | Meets the product standard's requirements. |
| **10.3 DEGREE OF PROTECTION OF ASSEMBLIES** | Does not apply, since the entire switchgear needs to be evaluated. |
| **10.4 CLEARANCES AND CREEPAGE DISTANCES** | Meets the product standard's requirements. |
| **10.5 PROTECTION AGAINST ELECTRIC SHOCK** | Does not apply, since the entire switchgear needs to be evaluated. |
| **10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS** | Does not apply, since the entire switchgear needs to be evaluated. |
| **10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS** | Is the panel builder's responsibility. |
| **10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS** | Is the panel builder's responsibility. |
| **10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH** | Is the panel builder's responsibility. |
| **10.9.3 IMPULSE WITHSTAND VOLTAGE** | Is the panel builder's responsibility. |
| **10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL** | Is the panel builder's responsibility. |
| **EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID** | 0 W |
| **HEAT DISSIPATION CAPACITY PDISS** | 0 W |
| **HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID** | 0 W |
| **RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)** | 0 A |
| **STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS** | 0 W |

## General information

| | |
|---|---|
| **DEGREE OF PROTECTION** | NEMA 4X, 13 |
| **DEGREE OF PROTECTION (FRONT SIDE)** | IP66 |
| **LIFESPAN, MECHANICAL** | 100,000 Operations |
| **MOUNTING POSITION** | As required |
| **OPENING DIAMETER** | 22.5 mm |
| **OPERATING FREQUENCY** | 2000 Operations/h |
| **OPERATING TORQUE** | 0.3 Nm |
| **OVERVOLTAGE CATEGORY** | III |
| **POLLUTION DEGREE** | 3 |
| **PRODUCT CATEGORY** | RMQ-Titan |
| **SIZE** | Front diameter: 29.7 mm |
| **SUITABLE FOR** | Illumination |
| **SWITCHING ANGLE** | 60 ° |
| **TYPE** | Illuminated selector switch actuator |

## Resources

| | |
|---|---|
| **CATALOGUES** | eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf<br><br>eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf |
| **DECLARATIONS OF CONFORMITY** | eaton-key-operated-actuator-declaration-of-conformity-eu251544en.pdf |
| **DRAWINGS** | eaton-operating-switch-m22-dimensions.eps<br><br>eaton-operating-switch-m22-dimensions-002.eps<br><br>eaton-general-m22-symbol.eps<br><br>eaton-general-m22-standards.eps<br><br>eaton-general-approval-m22-symbol.eps<br><br>eaton-operating-button-symbol-004.eps |
| **ECAD MODEL** | ETN.216828.edz |
| **INSTALLATION INSTRUCTIONS** | IL047160022 |
| **MCAD MODEL** | DA-CS-wahltaste_knebel |

| | |
|---|---|
| **PROJECT NAME:** | |
| **PROJECT NUMBER:** | |
| **PREPARED BY:** | |
| **DATE:** | |

**Eaton Corporation plc** Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

Follow us on social media to get the latest product and support information.

© 2026 Eaton. All Rights Reserved.