Specifications



Photo is representative





Eaton 229490

Eaton Moeller® series M22 Potentiometer, Classical, M22, 22.5 mm, R 4.7 kΩ, P 0.5 W, Bezel: titanium

General specifications	
PRODUCT NAME	Eaton Moeller® series M22 potentiometer
CATALOG NUMBER	229490
MODEL CODE	M22-R4K7
EAN	4015082294908
PRODUCT LENGTH/DEPTH	70 mm
PRODUCT HEIGHT	29 mm
PRODUCT WIDTH	29 mm
PRODUCT WEIGHT	0.034 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	UL 508 EN 60947-5 IEC 60947-5 CSA Std. C22.2 No. 94-91 CSA Std. C22.2 No. 14-05 CSA Class No.: 3211-03 IEC/EN 60947-5 CSA IEC/EN 60947 CSA-C22.2 No. 94-91 CSA-C22.2 No. 14-05 CE UL Category Control No.: NKCR CSA File No.: 012528 UL File No.: E29184 VDE 0660 UL

Actuator

BEZEL COLOR	Titanium
DESIGN	Classical
ELECTRIC CONNECTION TYPE	Screw connection
FITTED WITH:	3 individual screw terminals

Communication

CONNECTION TO SMARTWIRE-DT	No

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Design verification

10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.

10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0.5 W

Electrical rating

POWER CONSUMPTION	0.5 W
RATED INSULATION VOLTAGE (UI)	250 V
RATED POWER	0.5 VA
RESISTANCE	4700 Ohm

General information

DEGREE OF PROTECTION	IP66 NEMA Other
LIFESPAN, MECHANICAL	25,000 Operations
MOUNTING POSITION	As required
OPENING DIAMETER	22.5 mm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	4000 V AC
TYPE	Potentiometer

Terminal capacities

TERMINAL CAPACITY (SOLID)	0.5 - 1.5 mm²
TERMINAL CAPACITY (STRANDED)	0.5 - 1.5 mm²
TIGHTENING TORQUE	0.5 Nm, Screw terminals

Resources

CATALOGUES	eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf
DECLARATIONS OF CONFORMITY	eaton-potentiometer-declaration-of-conformity-eu251540en.pdf
DRAWINGS	eaton-operating-potentiometer-m22-dimensions-003.eps eaton-general-approval-m22-symbol.eps eaton-general-m22-symbol.eps eaton-general-m22-standards.eps
ECAD MODEL	ETN.229490.edz
INSTALLATION INSTRUCTIONS	IL04716002Z IL047030ZU
MCAD MODEL	DA-CS-potentiometer
PEP ECO-PASSPORT	eaton-potentiometers-pep-eato-00324-v0101-en.pdf
WIRING DIAGRAMS	eaton-operating-potentiometer-m30-wiring-diagram.eps

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	

Eaton Corporation plc Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

Follow us on social media to get the latest product and support information.

© 2026 Eaton. All Rights Reserved.